Reproduced from the holdings of the National Archives
Pacific Southwest Region

HN-02

RR UHPJC

DE LA254/UWLJAX 78

R 262147Z

AEC GRNC

REPOSITORY

COLLECTION

BOX NO.

FOLDER

FROM HOW NAN LOSA

TO HOW NAN ENIWETOK

/~~RESTRICTED~~/ ~~SECURITY~~ INFORMATION

HOW NAN NINE SEVEN SIX FOUR PD

DIETZE FROM DAVE NARVER JR PD RE STATION ONE TWO ONE ZERO DOG CMM REF DWG SIX TWO FOUR NINE CMM SIX TWO THREE EIGHT AND SIX TWO ONE EIGHT PD CLEAR HEIGHT OF TYPE NINE DOOR OPENING SHOWN ON DWG SIX TWO FOUR NINE AND DWG SIX TWO THREE EIGHT SECTION ABLE MUST BE INCREASED FROM SEVEN FEET NINE INCHES TO EIGHT FEET TWO INCHES PD FIELD SPLICE THE EIGHT BY SIX BY FIVE SLASH EIGHT DOOR FRAME ANGLES SHOWN ON DWG SIX TWO ONE EIGHT AT A POINT ABOVE THE TOP HINGE TO GIVE THE REQUIRED FIVE INCH EXTRA HEIGHT PD SKETCH SHOWING REQUIRED FIELD REWORK OF TYPE NINE DOOR WILL FOLLOW PD

DEPARTMENT OF ENERGY DECLASSIFICATION REVIEW
SINGLE REVIEW AUTHORIZED BY: AAS in Sagalli 7-22-94
REVIEWER (ADD): NAME: J.D. LAZUK DATE: 7/29/94
1 DETERMINATION (FOREIGN NUCLEAR)
2 CLASSIFICATION RETAINED
3 CLASSIFICATION CHANGED TO
4 CONTAINS NO DOE CLASSIFIED INFO
5 COORDINATE WITH
6 CLASSIFICATION CANCELLED
7 CLASSIFIED INFO BRACKETED

26/2151Z