Reproduced from the holdings of the National Archives

HN-05

RR UHPJC

DF LA254/UWFJAX GO

R 162308/

AEC GRNC

FM HOW NAN LOSA

PASS TO HOW NAN ENIWETOK

/RESTRICTED/ SECURITY INFORMATION

HOW NAN NINE SIX SEVEN TWO PD

EDWARDS FROM DAVE NARVER IN PD REDR PRESS FOUR SIX FOUR FIVE PD

NEITHER PUMPS NOR GENERATORS REQUIRE ANCHOR BOLTS BECAUSE OF

SPECIAL VIBRATION MOUNTINGS PD BOTTOM SLAB STEEL NOT RPT NOT

CONTINUOUS THRU EQUIPMENT FOUNDATIONS AND VEE DASH SHAPED COPPER WATER

STOP CMM SOLDERED AT CORNERS CMM TO BE PROVIDED AROUND ALL

FOUNDATIONS PD VENDOR DWGS APPROVED AND TRANSMITTAL BEING

EXPEDITED PD

SING
AA Sinisgalli 7-23-
REVIEWER (AGO)
NAME
DATE 7/29/9

16/23142