

RECEIVED

DISPATCHED
OCT 15 1952

R

EXEC VICE PRES	
V. P. & GEN. MGR	
CH. FISCAL OFFICER	
ASST. GEN. MGR	I
OPER. MGR	I
IND. REL. MGR	
PERSON. MGR	
EST. MGR	
CH. ENG. DIVISION	
DEPT. ENGR.	
CH. INSTR. DIVISION	
CH. RESEARCH	
CH. SALES	884
SALES	
ADVISORY	
SECURITY	

I
A
K
D
M

DEPARTMENT OF ENERGY DECLASSIFICATION REVIEW

SINGLE REVIEW AUTHORIZED BY: ANS/mgalli 7/23/94

REVIEWER (ACC): J.D. LAZAR

NAME: J.D. LAZAR

DATE: 7/29/94

DETERMINATION (PROJECT NUMBER(S))
 1. CLASSIFIED INFORMATION
 2. CLASSIFIED INFORMATION
 3. CLASSIFIED INFORMATION
 4. CLASSIFIED INFORMATION
 5. CLASSIFIED INFORMATION
 6. CLASSIFIED INFORMATION
 7. CLASSIFIED INFORMATION
 8. CLASSIFIED INFORMATION
 9. CLASSIFIED INFORMATION
 10. CLASSIFIED INFORMATION

CLASSIFICATION CANCELLED
 0. CLASSIFIED INFO BRACKETED

~~SECURITY INFORMATION~~
~~RESTRICTED~~

PRIORITY

"This material contains information affecting the national defense of the United States within the meaning of the espionage laws, Title 18, U.S.C., Secs. 793 and 794, the transmission or revelation of which in any manner to an unauthorized person is prohibited by law."

ans 10/15
PRIORITY REPLY

Steel substitutions proposed ENGMSG 4631 satisfactory x slow on as-built.

ACTION

WUC72
HUF039
HA038
PP UWLX

DE UHPJC 36
T LA254
P 150444Z

AEC GRNC

FROM HOW NAN ENIWETOK
TO HOW NAN LOSA
CITE ENGMSG FOUR SIX THREE ONE

~~RESTRICTED~~

DAVID NARVER JR FROM CORAY PD QUOTE EDWARDS FROM HARBERT PD IT IS REQUESTED THAT AUTHORIZATION BE GIVEN TO SUBSTITUTE NUMBER ONE ZERO BAR AT FOUR AND EIGHT INCHES FOR NUMBER ONE ONE BARS AT FIVE AND ONE ZERO INCHES CMM STATION ONE THREE FOUR ONE PD IT IS ALSO REQUESTED TO SUBSTITUTE NUMBER ONE ZERO BARS AT FIVE AND NINE AND ONE HALF INCHES FOR NUMBER ONE ONE AT SIX AND ONE TWO INCHES CMM STATION ONE TWO ONE ZERO PD IT IS ALSO REQUESTED TO SUBSTITUTE NUMBER ONE ZERO AT FOUR INCHES FOR NUMBER ONE ONE AT FIVE INCHES CMM STATION ONE TWO ZERO ZERO

PD IS URGENT THAT ACTION BE TAKEN UPON THIS IMMEDIATELY AS STEEL WORK WILL BE HELD UP PD UNQUOTE PLEASE ADVISE PRIORITY TELETYPE
W 15/0452Z

Sta. 12.10