Reproduced from the holdings of the National Archives
Pacific Southwest Region

Field Manager
Eniwetok Field Office
P. O. Box 5400
Albuquerque, New Mexico

September 17, 1953

BEST COPY AVAILABLE

Subject: Station 1341

Dear Sir:

Reference your letter PG-5-3209 dated September 10, 1953.

In reply to your question regarding drawing 6260-DE-3, we are using the P-3000 series unistrut as a satisfactory substitute for the P-1000 series due to the fact that the P-1000 series is no longer manufactured.

Very truly yours,

HOLMES & NARVER, INC.

David L. Narver, Jr.
Chief Project Engineer

DLNJr:eas

cc: P. W. Spain, AEC
Robert H. Campbell, J-Div., U.S.
Constr.-Op. [illegible] (2)
Project E[illegible]
[illegible] (2)

DEPARTMENT OF ENERGY DECLASSIFICATION
SINGLE REVIEW AUTHORIZED BY
AA Sinisgalli 7-23-94
REVIEWER (ADD)
NAME J.D. Cazon
DATE 7/29/94