Reproduced from the holdings of the National Archives
Pacific Regional Branch

SENT

| | |
|---|---|
| PRESIDENT | |
| EXEC VICE PRES | |
| V PRES & GEN MGR | |
| CH FISCAL OFFCR | |
| ASST GEN MGR | ✓ |
| OPERATIONS | ✓ |
| INDUS RELATIONS | |
| PROCUREMENT | |
| ESTIMATION | |
| OFFICE MANAGER | |
| [illegible] | |
| [illegible] | |
| [illegible] | ✓ |
| PROJ ENGR | |
| SALES DIVISION | |
| ACCOUNTING | |
| SECURITY | |

N-10

RR UHPJ

SECURITY INFORMATION
RESTRICTED

DE UWFJA

R 161755

ALC CR7

[illegible] AVAILABLE

This material contains information affecting the [illegible] States within the meaning [illegible] Secs. [illegible] of which in any [illegible] prohibited by law.

PAREN ~~RESTRICTED~~ PAREN ~~SECURITY~~ INFORMATION PD FROM HOW NAN LOSA PASS TO HOW NAN ENIWEIOL PD HOW NAN [illegible] PD SOLTICHER FROM DAVE NARVER [illegible] PD REFERENCE TO [illegible] PD MAXIMUM SOIL PRESSURE GIVEN ON STRUCTURAL DWG IS THE MAXIMUM PRESSURE THAT THE FOUNDATION WILL HAVE TO WITHSTAND PD NO BEARING TEST WILL BE REQUIRED UNLESS IT IS OBVIOUS THAT THE SOIL WILL NOT BE ABLE TO TAKE THE PRESSURE INDICATED PD

16/1758A

SECURITY INFORMATION
RESTRICTED

DEPARTMENT OF ENERGY [illegible]
SINGLE REVIEW AUTHORITY [illegible]
REVIEWER (AUTH)
NAME [illegible]
DATE [illegible]