



SRS Energy Performance Metrics



Savannah River Site Buildings Energy Use Index

Fiscal Year	Electricity Mbtu/Sqft	Fuel Oil Mbtu/Sqft	LPG Mbtu/Sqft	Coal Mbtu/Sqft	Steam Mbtu/Sqft	Total Mbtu/Sqft
2003	0.1837	0.0103	0.0000	0.0418	0.1926	0.4285
1985	0.1621	0.0331	0.0000	1.7329	0.000	1.9281
% Diff	13.33%	-68.81%	0.00%	-97.59%	+	77.78%

Savannah River Site Industrial Facilities Energy Use Index

Fiscal Year	Electricity Mbtu/Sqft.	Fuel Oil Mbtu/Sqft.	LPG Mbtu/Sqft.	Coal Mbtu/Sqft.	Steam Mbtu/Sqft	Total Mbtu/Sqft.
2003	0.1082	0.0612	0.0000	0.0000	0.0571	0.2265
1990	0.2590	0.0151	0.0022	0.3270	0.0000	0.6033
% Diff	-58.2%	306.6%	-98.7%	-100.0%	0.0%	-62.5%